

SUPPLEMENTAL BID BULLETIN

**Republic of the Philippines
PHILIPPINE INTERNATIONAL CONVENTION CENTER
PICC Complex, 1307 Pasay City
BIDS AND AWARDS COMMITTEE (BAC)**

October 30, 2024

**SUPPLY OF LABOR AND MATERIALS FOR CORRECTIVE WORKS FOR THE FAN
COIL UNIT (FCU) DRAIN LINES OF VARIABLE REFRIGERANT VOLUME (VRV),
MULTI-SPLIT, INVERTER-TYPE PACKAGED AIR CONDITIONING UNITS (PACUs)
SERVING SUMMIT HALLS C, D, E, F AND OTHER AREAS**

ADDENDUM NO. 01

This Addendum is issued to amend/revise certain provisions of the Bid Documents for the above-captioned procurement. Said amendments are as follows:

I. Section VII- Technical Specifications have been revised to read as:

• **II. SPECIAL/OTHER CONDITIONS OF THE CONTRACT:**

- **2.** All drain pumps to be supplied shall conform with the technical specifications as needed/required for the **project**.
- **3.** The Contractor must submit sample of drain pump, pvc drain pipe, pvc fitting, rubber insulation (1" thick), polyethylene tape for **approval of the end-user** prior to installation.

II. Section VIII- Checklist of Requirements has been revised to read as:

• **II. FINANCIAL COMPONENT ENVELOPE**

- (f) Original of duly signed and accomplished Financial Bid Form;
- (g) Bill of Quantities - **deleted**

The corrected copies are attached. Bidders are advised to replace their original copies with the corrected copies.

For guidance and information of all concerned.


WILSON B. DELOS REYES
Chairman

Received by:

(Signature over printed name)
Telephone/Fax No. _____
Date: _____
Name of Company: _____

Technical Specifications

Item	Specification	Statement of Compliance
	<p>Project: SUPPLY OF LABOR AND MATERIALS FOR THE CORRECTIVE WORKS FOR THE FAN COIL UNIT (FCU) DRAIN LINES OF VARIABLE REFRIGERANT VOLUME (VRV), MULTI-SPLIT, INVERTER-TYPE PACKAGED AIR CONDITIONING UNITS (PACUs) SERVING SUMMIT HALLS C, D, E, F AND OTHER AREAS</p> <p>I. SPECIFIC SCOPE OF WORKS:</p> <p>Supply of labor, materials, tools/instruments, technical expertise, supervision and safety watch for the corrective works for the FCU Drain Lines of Variable Refrigerant Volume (VRV) Multi-split, Inverter-type PACUs serving Summit Halls C, D, E, F and Delegation Main Lobby and other areas to include but not limited to the following:</p> <ol style="list-style-type: none"> 1. Supply, deliver and install new 28 units Daikin Drain Pumps, model: KDU30L250AVE complete with accessories at Summit Halls C, D, E, F and Delegation Main Lobby 2. Properly drain the drain pipe sloping downwards to the designated floor drain/catch basin at a gradient of at least 1/100 to prevent air pockets and sludge/scale from forming. 3. Provide additional hangers and support, and arrange it to maintain not more than 5ft distance from every hangers and support to the existing drain pipe to prevent it from sagging and maintain gradient. Provide additional ceiling manholes as needed. 4. Provide additional drain pipe, fitting, insulation (1" thick), polyethylene tape with improved tapping in pipe if necessary. 5. Conduct flow test of the newly arranged/aligned drain pipes Compensate water must be from flowing and stream lined. 6. Turn-over the Air-conditioning System/Drain lines serving Summit Halls C, D, E, F and Delegation Main Lobby in good, proper operating condition. <p>II. SPECIAL/OTHER CONDITIONS OF THE CONTRACT:</p> <ol style="list-style-type: none"> 1. The Contractor before submitting his proposal should examine all issued documents relating to his work and verify all governing conditions at site. The Contractor shall report to PICC any condition that will prevent him from performing first class work. No consideration will be granted for any alleged misunderstanding and improper presentation of the equipment, parts and materials to be used and or work to be done. 2. All drain pumps to be supplied shall conform with the technical specifications as needed/required for the project. 	

<ol style="list-style-type: none"> 3. The Contractor must submit sample of drain pump, pvc drain pipe, pvc fitting, rubber insulation (1" thick), polyethylene tape for approval of the end-user prior to installation. 4. The Contractor shall ensure that its assigned personnel and/or representatives shall comply with, and submit themselves to, the rules and regulations of the PICC on security, sanitation, environmental compliance, safety and health protocols and other regulations. 5. All works to be conducted by the Contractor/assigned personnel must be coordinated properly with the Technical Services Department-Mechanical Services Division (TSD-MSD). 6. The winning Contractor shall restore/repair and or replace immediately at his own expense any damaged mechanical equipment/systems and properties occasioned by and/ or due to Contractor's fault or negligence during the drain pump installation & condensate drain line corrective work and during the one (1) year warranty period. 7. The Contractor should free the PICC and its personnel from and against all liabilities arising from injuries or liabilities to persons or damages to property occasioned by any act or omissions by the Contractor. 8. The Contractor must submit NBI or Barangay Clearance of each personnel to be assigned at the PICC. 9. The Contractor's personnel should wear its company uniform/ID at all times in the PICC premises. 	
<p style="text-align: center;">STATEMENT OF COMPLIANCE</p> <p><i>Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered.</i></p>	

Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.

Checklist of Technical and Financial Documents

I. TECHNICAL COMPONENT ENVELOPE

Class “A” Documents

Legal Documents

- ☐ (a) Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages) **in accordance with Section 8.5.2 of the IRR. If any of the documents in Annex “A” has expired, the updated document shall be submitted during post-qualification;**

Technical Documents

- ☐ (b) Statement of the prospective bidder of all its ongoing government and private contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid (**Annex “A”**); **and**
- ☐ (c) Statement of the bidder’s Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided for in Sections 23.4.1.3 and 23.4.2.4 of the 2016 revised IRR of RA No. 9184, within the relevant period as provided in the Bidding Documents (**Section “B”**); **and**
- ☐ (d) Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission or Original copy of Notarized Bid Securing Declaration (**Annex C**); **and**
- ☐ (e) Fully accomplished **Section VI (Schedule of Requirements)** and **Section VII (Technical Specifications)** signed on each and every page, including the drawing, if any; **and**
- ☐ (f) Original duly signed Omnibus Sworn Statement (OSS) **and** if applicable, Original Notarized Secretary’s Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder (**Annex “D”**).

Financial Documents

- ☐ (g) The prospective bidder’s computation of Net Financial Contracting Capacity (NFCC) (**Annex “E”**) or A committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation.

Class “B” Documents

- ☐ (h) If applicable, a duly signed joint venture agreement (JVA) in case the joint venture is already in existence or duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.

II. FINANCIAL COMPONENT ENVELOPE

- ☐ (i) Original of duly signed and accomplished Financial Bid Form;